



Tumakuru City Corporation, Tumakuru

Website: www.tumkurcity.org, 111-4-1-Du, 111
E-mail: tumkur_ull_tumkur@yahoo.com

Phone: 22711-110, Fax: 2275111
Gr. No. mc-c:U816-22712UO, 227220



Water Quality Testing Laboratory, PNR Palya

TESTREPORT

Sample Received on: 04-02-2026

Report Date : CR-No-265,06-02-2026

Analysis Date: 04-02-2026

Sample From : Rotary HS C N Halli Ward - 05, Shettikere road Chikkanayakanahalli- 572214, Tumkur(Dist),
Karnataka(State).

Sl.No.	Test Parameter	Result	Limits as per IS10500:2012	
			Acceptable	Permissible
(A)	Physical Parameters			
1	Temperature	25		
2	Odour	Agreeable	Agreeable	Agreeable
3	Taste	Agreeable	Agreeable	Agreeable
4	Colour, Hazen U01its	S	S	15
(B)	Chemical Parameters			
5	PH	7.02	6.5-8.5	No Relaxation
6	Turbidity in NTU	0	1	S
7	Total Dissolved Solids in mg/l	168.6	500	2000
8	Total Hardness as CaCO3 in mg/l	60	200	600
9	Flouride in ppm	Absent	1	1.5
10	Nitrate in ppm	Absent	45	No Relaxation
11	Free-residual Chlorine in ppm	Absent	1	1.5
12	Iron in ppm	Absent	1	No Relaxation
(C)	Microbiological Parameters			
13	E-Coil	0	Absent	Absent
14	Total Coliform	0	Absent	Absent

Remarks: 1) All Tested Parameters are found to be within Acceptable limits as per IS10500:2012

Analyzed by 06/04/26

Authorised sign
ಸವಾಯಕ ಅಭಿಯಂತರರು
ಮಹಾನಗರ ಪಾಲಿಕೆ, ತುಮಕೂರು.

Content of the Top Corner Seal is
Translated From Kannada to English

Tumakuru City Corporation
Tumakuru

Content of the
Seal is Translated from Kannada to English



M.B. NAGARAJ M.A., LL.B.,
ADVOCATE & NOTARY PUBLIC
KAR - 454/1999
Reg.No.10177
C N HALLI - 572214

Sd/-
Assistant Engineer
Metropolitan City
Tumakuru



Tumakuru City Corporation, Tumakuru

website : www.tumkurcity.mrc.gov.in
e-mail: itstaff_ulb_tumkur@yahoo.com

Phone : 2278480, Fax: 2275106

Grievance: 0816-2271200, 2272200



Water Quality Testing Laboratory, PNR Palya

TEST REPORT

Sample Received on: 04-02-2026

Report Date: CR-No- 265,06-02-2026

Analysis Date: 04-02-2026

Sample From: ROTARY HS CN HALLI Ward-05, Shettikere road Chikkanayakanahalli-572214, Tumkur (Dist), Karnataka (State).

Sl.No.	Test Parameter	Result	Limits as per IS 10500:2012	
			Acceptable	Permissible
(A)	Physical Parameters			
1	Temperature	25		
2	Odour	Agreeable	Agreeable	Agreeable
3	Taste	Agreeable	Agreeable	Agreeable
4	Colour, Hazen Units	<05	5	15
(B)	Chemical Parameters			
5	PH	7.02	6.5-8.5	No Relaxation
6	Turbidity in NTU	0	1	5
7	Total Dissolved Solids in mg/l	168.6	500	2000
8	Total Hardness as CaCO ₃ in mg/l	60	200	600
9	Flouride in ppm	Absent	1	1.5
10	Nitrate in ppm	Absent	45	No Relaxation
11	Free-residual Chlorine in ppm	Absent	1	1.5
12	Iron in ppm	Absent	1	No Relaxation
(C)	Microbiological Parameters			
13	E-Coil	0	Absent	Absent
14	Total Coliform	0	Absent	Absent

Remarks: 1) All Tested Parameters are found to be within Acceptable limits as per IS10500:2012.

Analyser
Analysed by *RM*
06/02/26

Authorised sign
Authorised sign
ಸಮಾಜಕ ಅಭಿವೃದ್ಧಿ
ಮಂಡಳಿಯ ಮಂಡಿ, ಮುಖ್ಯಮಂತ್ರಿ.

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No:

Dated: 03-02-2026

It is certified that an inspection team headed by **Manjunath Engineer Town Municipality, Chikkanayakanahalli - 572214** (Name of Officers with designation) from **Chikkanayakanahalli PHED**

Inspected the **ROTARY HS C N HALLI**, Ward NO. 5, Shettikere Road, Chikkanayakanahalli Town, Tumkur Dist, Karnataka (S) (Name & Address of the school) on 03-02-2026 (date of inspection) **and on the basis of Water Test Report (Attached) bearing no CR NO 265, 06-02-26 dated: 03/02/2026** of Chikkanayakanahalli (PHED Lab) certified that the **ROTARY HS C N HALLI** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 03/02/2026 to 02/02/2027

Signature with Seal

JUNIOR ENGINEER

Name

TOWN MUNICIPALITY OFFICER

Designation

Engineer

Name & Address of the Office / Department

Town Municipality

C N Halli - 572214

Tumkur, Karnataka

To

ROTARY HS C N HALLI

Ward no - 5, Shettikere Road

Chikkanayakanahalli - 572214

Tumkur Dist, Karnataka (S)

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED-Lab / local bodies

Content of the Top Corner Seal is
Translated From Kannada to English

Town Municipality
Chikkanayakanahalli



M.B. NAGARAJ M.A., LL.B.,
ADVOCATE & NOTARY PUBLIC

KAR - 434/1999

10177

572214

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No:

Dated: 03-02-2026

It is certified that an inspection team headed by **Manjunath Engineer Town Municipality, Chikkanayakanahalli - 572214** (Name of Officers with designation) from **Chikkanayakanahalli PHED**

Inspected the **ROTARY HS C N HALLI**, Ward NO. 5, Shettikere Road, Chikkanayakanahalli Town, Tumkur Dist, Karnataka (S) (Name & Address of the school) on 03-02-2026 (date of inspection) **and on the basis of Water Test Report (Attached) bearing no CR NO 265, 06-02-26 dated: 03/02/2026** of Chikkanayakanahalli (PHED Lab) certified that the **ROTARY HS C N HALLI** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 03/02/2026 to 02/02/2027

Signature with Seal

: JUNIOR ENGINEER

Name

: TOWN MUNICIPAL COUNCIL
Chikkanayakanahalli

Designation

: Engineer

Name, & Address of the Office / Department

: Town Municipality

C N Halli - 572214

Tumkur, Karnataka

To

ROTARY HS C N HALLI

Ward no - 5, Shettikere Road

Chikkanayakanahalli - 572214

Tumkur Dist, Karnataka (S)

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED-Lab / local bodies