



# Tumakuru City Corporation, Tumakuru

Website: www.tumkurcity.tn.tn.gov.in  
E-mail: info@tumkurcity.tn.tn.gov.in

Phone: 227114 HO, Fax: 2275111  
Grt. No. U816-22712UO, 227220



## Water Quality Testing Laboratory, PNR Palya

### TEST REPORT

Sample Received on: 04-02-2026

Report Date: CR-No-265, 06-02-2026

Analysis Date: 04-02-2026

Sample From: Rotary English Higher Primary & High School, Shettikererod, Ward-05, Chikkanayakanahalli-572214, Tumkur(D), Karnataka(S).

Sl.No.	Test Parameter	Result	Limits as per IS 10500:2012	
			Acceptable	Permissible
<b>(A) Physical Parameters</b>				
1	Temperature	25		
2	Odour	Agreeable	Agreeable	Agreeable
3	Taste	Agreeable	Agreeable	Agreeable
4	Colour, Hazen U01ts	S	S	15
<b>(B) Chemical Parameters</b>				
5	PH	7.02	6.5-8.5	No Relaxation
6	Turbidity in NTU	0	1	S
7	Total Dissolved Solids in mg/l	168.6	500	2000
8	Total Hardness as CaCO3 in mg/l	60	200	600
9	Fluoride in ppm	Absent	1	1.5
10	Nitrate in ppm	Absent	45	No Relaxation
11	Free-residual Chlorine in ppm	Absent	1	1.5
12	Iron in ppm	Absent	1	No Relaxation
<b>(C) Microbiological Parameters</b>				
13	E-Coli	0	Absent	Absent
14	Total Coliform	0	Absent	Absent

Remarks: 1) All Tested Parameters are found to be within Acceptable limits as per IS 10500:2012

Analyzed by: *[Signature]*  
06/04/26

*[Signature]*  
Authorised sign  
ಸಹಾಯಕ ಅಭಿಯಂತರರು  
ಪುನಃನಗರ ವಾಹಿನಿ, ತುಮಕೂರು.

Content of the Top Corner Seal is Translated From Kannada to English

Tumakuru City Corporation

Tumakuru



Content of the Seal is Translated from Kannada to English

Sd/-

Assistant Engineer  
Metropolitan City  
Tumakuru

*[Signature]*  
M. B. NAGARAJ, B.A., LL.B.,  
Advocate & Notary  
C. N. Halli - 572214  
Reg. No. 10177



**Tumakuru City Corporation, Tumakuru**

website : www.tumkurcity.mrc.gov.in  
e-mail: itstaff\_ulb\_tumkur@yahoo.com

Phone: 2278480, Fax: 2275106

Grievance: 0816-2271200, 2272200



**Water Quality Testing Laboratory, PNR Palya**

**TEST REPORT**

Sample Received on: 04-02-2026

Report Date: CR-No- 265,06-02-2026

Analysis Date: 04-02-2026

Sample From: ROTARY HS CN HALLI Ward-05, Shettikere road Chikkanayakanahalli-572214, Tumkur (Dist), Karnataka (State).

Sl.No.	Test Parameter	Result	Limits as per IS 10500:2012	
			Acceptable	Permissible
<b>(A) Physical Parameters</b>				
1	Temperature	25		
2	Odour	Agreeable	Agreeable	Agreeable
3	Taste	Agreeable	Agreeable	Agreeable
4	Colour, Hazen Units	<05	5	15
<b>(B) Chemical Parameters</b>				
5	PH	7.02	6.5-8.5	No Relaxation
6	Turbidity in NTU	0	1	5
7	Total Dissolved Solids in mg/l	168.6	500	2000
8	Total Hardness as CaCO3 in mg/l	60	200	600
9	Flouride in ppm	Absent	1	1.5
10	Nitrate in ppm	Absent	45	No Relaxation
11	Free-residual Chlorine in ppm	Absent	1	1.5
12	Iron in ppm	Absent	1	No Relaxation
<b>(C) Microbiological Parameters</b>				
13	E-Coil	0	Absent	Absent
14	Total Coliform	0	Absent	Absent

Remarks: 1) All Tested Parameters are found to be within Acceptable limits as per IS10500:2012

*Analyser's Signature*  
Analysed by 06/02/26

*Authorised sign*

Authorised sign  
ಸಹಾಯಕ ಅಭಿಯಂತರರು  
ಪುನಃನಗರ ಪಾಲಿಕೆ, ಪುನಃನಗರ.

*Secretary's Signature*  
SECRETARY

Rotary HS C N Halli  
Shettikere Road, Chikkanayakanahalli-572214  
Tumkur Dist, Karnataka

*Principal's Signature*  
PRINCIPAL

Rotary HS C N Halli  
Shettikere Road, Chikkanayakanahalli-572214  
Tumkur Dist, Karnataka

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No:

Dated: 03-02-2026

It is certified that an inspection team headed by **Manjunath Engineer Town Municipality, Chikkanayakanahalli - 572214** (Name of Officers with designation) from **Chikkanayakanahalli PHED**

Inspected the **ROTARY HS C N HALLI**, Ward NO. 5, Shettikere Road, Chikkanayakanahalli Town, Tumkur Dist, Karnataka (S) (Name & Address of the school) on 03-02-2026 (date of inspection) **and on the basis of Water Test Report (Attached) bearing no CR NO 265, 06-02-26 dated: 03/02/2026** of Chikkanayakanahalli (PHED Lab) certified that the **ROTARY HS C N HALLI** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 03/02/2026 to 02/02/2027

Signature with Seal

Name

Designation

Name &amp; Address of the Office / Department

**JUNIOR ENGINEER**  
**TOWN MUNICIPALITY**  
**CHIKKANAYAKANAHALLI**

Engineer

Town Municipality

C N Halli - 572214

Tumkur, Karnataka

To

**ROTARY HS C N HALLI**

Ward no - 5, Shettikere Road

Chikkanayakanahalli - 572214

Tumkur Dist, Karnataka (S)

(Name &amp; Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED-Lab / local bodies

Content of the Top Corner Seal is  
Translated From Kannada to English

Town Municipality  
Chikkanayakanahalli

**M.B. NAGARAJ M.A.L.L.B.**  
ADVOCATE & NOTARY PUBLIC  
KAR - 454/1999  
Reg.No.10177  
C N HALLI - 572214



# Annexure C


## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 03-02-2026

It is certified that an inspection team headed by **Manjunath Engineer Town Municipality, Chikkanayakanahalli - 572214** (Name of Officers with designation) from **Chikkanayakanahalli PHED**

Inspected the **ROTARY HS C N HALLI, Ward NO. 5, Shettikere Road, Chikkanayakanahalli Town, Tumkur Dist, Karnataka (S)** (Name & Address of the school) on 03-02-2026 (date of inspection) **and on the basis of Water Test Report (Attached) bearing no CR NO 265, 06-02-26 dated: 03/02/2026** of Chikkanayakanahalli (PHED Lab) certified that the **ROTARY HS C N HALLI** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the **hygienic sanitation** condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.


This certificate is valid till 03/02/2026 to 02/02/2027


Signature with Seal :   
Name : JUNIOR ENGINEER  
Designation : TOWN MUNICIPAL COUNCIL  
CHIKKANAYAKANAHALLI  
Engineer  
Name & Address of the Office / Department : Town Municipality  
C N Halli - 572214  
Tumkur, Karnataka

To  
**ROTARY HS C N HALLI**

Ward no - 5, Shettikere Road  
Chikkanayakanahalli - 572214  
Tumkur Dist, Karnataka (S)  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED-Lab / local bodies

  
SECRETARY  
Rotary HS C N Halli  
Shettikere Road, Chikkanayakanahalli-572214  
Tumkur Dist, Karnataka

  
PRINCIPAL  
Rotary HS C N Halli  
Shettikere Road, Chikkanayakanahalli-572214  
Tumkur Dist, Karnataka